

ICC-ES Listing Report

ESL-1022

Reissued July 2022 This listing is subject to renewal July 2023.

www.icc-es.org | (800) 423-6587 | (562) 699-0543

A Subsidiary of the International Code Council®

CSI: DIVISION: 07 00 00—THERMAL AND MOISTURE PROTECTION

Section: 07 25 00—Water-resistive Barriers/Weather Barriers

Product Certification System:

The ICC-ES product certification system includes testing samples taken from the market or supplier's stock, or a combination of both, to verify compliance with applicable codes and standards. The system also involves factory inspections, and assessment and surveillance of the listee's quality system.

Product: TAMLYNWRAP™ HOUSEWRAP

Listee: R.H. TAMLYN & SONS LP

Evaluation: The TamlynWrap™ Housewrap, was evaluated based on testing to the following standards:

■ UL 723-2008 and -03, Tests for Surface Burning Characteristics of Building Materials

ASTM E84-09 and -07, Standard Test Method for Surface Burning Characteristics of Building Materials

Findings: The TamlynWrap™ Housewrap has a flame spread index of 25 or less, and smoke developed index of 450

or less, per UL723/ASTM E84.

Identification:

- Each roll of the TamlynWrap[™] Housewrap is identified with a label indicating the manufacturer's name, logo and website address, the product name and the listing number (ESL-1022) and/or the ICC-ES evaluation report number (ESR-3670).
- 2. The report holder's contact information is the following:

R.H. TAMLYN & SONS LP 13623 PIKE ROAD STAFFORD, TEXAS 77477-5103 (281) 499-9604 (800) 384-1676 www.tamlynwrap.com

Installation: The product must be installed in accordance with the R.H. Tamlyn & Sons instructions.

Conditions of listing:

- The listing addresses only conformance with the standards and code sections noted above. Additional
 information can be found in ICC-ES evaluation report <u>ESR-3670</u>.
- Approval of the product's use is the sole responsibility of the local code official.

